



aitex[®]
research & innovation center

REACTION TO FIRE

Applicant:

GABRIEL A/S

HJULMAGERVEJ, 55
DK-9000 Ålborg

Is authorized to place the label "Classification of Reaction to Fire of Construction Products" according to the 2025AN0607.



CLASSIFICATION OF REACTION TO FIRE OF: CONSTRUCTION PRODUCTS

Nº: 25AN0607

The sample referenced as:

"Art.Event Screen col.61008"

has been tested according to the standards EN ISO 11925-2:2020 & EN 13823:2020 + A1:2022. The classification according to standard EN 13501-1:2018 is:

"B-s1,d0"

Date of Issue

27th of March 2025



Date: 27/03/2025 10:58:51

Digitally Signed by: JOAN RISUEÑO CABANES -

NIF: 48605765A

Joan Risueño
Head of Fire Behaviour lab.