



The applicant: **GABRIEL A/S**
HULMAGERVEJ 55
DK-9000 Ålborg

is authorized to place the label "Classification of Reaction to Fire of Construction Products " according to the report N° 2021AN1938



aitex
textile research institute

**CLASSIFICATION OF REACTION TO FIRE OF:
CONSTRUCTION PRODUCTS**

N° 21AN1938

The sample reference:

“Atlantic”

has been tested according to the standards EN ISO 11925-2:2020 and EN 13823:2010+A1:2014. The classification according to standard EN 13501-1:2018 is:

“B-s1,d0”

Alcoy, September 14th 2021.



CELIA DOLÇA CAMAÑEZ
- NIF:216961225
2021.09.14 10:43:26
+02'00'

Celia Dolça
HEAD OF FIRE BEHAVIOUR LAB.