



## Approval of the Trademark Trevira CS®

Gabriel A/S Hjulmagervej 55 9000 Aalborg Denmark

 Application No.:
 230492

 Date of issue:
 21.06.2023

 Valid until:
 21.06.2028

Article name: Step Melange Screen col grey 60504

End use: Drapes

Upholstery fabrics Wall coverings

Square weight (g/m²): 245

According to customer specification

**Composition of the raw materials:** Polyester 100% **Composition of the fabric:** Previra CS 100%

Yarn: Warp, 525 f 192 x 1 dtex Trevira® Type 5MVM 001,

Yarn supplier Indorama

Weft, 525 f 192 x 1 dtex Trevira® Type 5MVM 001,

Yarn supplier Indorama

The tested article Step Melange Screen col grey 60504 with application no. 230492 is granted approval for the trademark Trevira CS® for interior use.

This article was tested according to DIN 4102 part 1, 6.2 and thus also meets the requirements for fire class DIN 4102-B1.

The article was tested according to the French Standard NF P 92-504 (Propagation de flamme) and thus also meets the requirements for class M1 according to NF P 92-503, 92-505 and 92-507. This article meets the requirements according to EN 1021-1 and -2:2014 in conjunction with

polyurethan foams with a density of more than 30 kg/m<sup>3</sup>.

The article meets the requirements for class 1 according to EN 13773.

This article qualifies for class B-s1, d0 according to the European Standard EN 13501-1. Trevira CS has been approved by the DIBt with the General Building Inspectorate Approval, Approval No. Z-56.25-3573 dd. 24 April 2018.

Thus meets also the requirements for class 1 according to the Italian Standards UNI 8456 and UNI 8457. Thus meets also the requirements according to the Italian standard UNI 9175, class 1 IM in conjunction with suitable combustion modified foams.

Thus meets also the requirements according to British Standard BS 5867 part 2 type C.

Thus meets also the requirements according to British Standard BS 5852: ignition source 0 (cigarette), ignition source 1 (match) and ignition source 5 (crib 5) in conjunction with suitable combustion modified foams (at least 50 kg/m³).

This article also meets the requirements according to the North American standard NFPA 701: 2010 Test Method #1 (based on the Test Reports Govmark, New York No. 2-94779, 2-94780, 2-94781). This article also meets the requirements for class I according to the North American standard NFPA 260 for upholstered furniture (based on the Test Reports no. 10-002-775 A + B dated 24.11.2010).

Indorama Ventures Fibers Germany GmbH (This document is valid without signature.)